

Compliance Statement

No. 2025-499

Screened Channel, Class E_A

Company

Qubix S.p.A.
Via Canada 22/A
35127 Padova
Italy

Channel Identification (4 connector model)

Horizontal cable:

Qubix/CCS 10G.EXE STP Horizontal cable

Cords:

Qubix/CCS 10G.EXE STP Patch Cable

Wall Outlet:

Qubix/CCS 10G.EXE Shielded Jack (art. 2001016)

Patch Panel:

Qubix/CCS 19" Patch Panel equipped with CCS 10G. EXE Shielded Jack

Generic cabling standards - Class E_A Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-E:2024

Technical report

12528364-02, DANAK-19/25191

EC Cabling product ID


5095

CS valid until


1 September 2026

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 22 August 2025



Nis Jepsen
Specialist, Project Manager



Lars Lindskov Pedersen
Senior Team Leader, Test Manager